

District Name: Khagaria
 Sample Collected By: School Manager (Reg.no : 223132220231012114419)

Government of Bihar
 Public Health Engineering Department
 Monthly Water Quality Monitoring Report
 Division Name: P.H.Division, Khagaria

District Lab, Khagaria
 Month:- June - 2025

Sl. No.	Sample Code	Block	Panchayat	Village/ Ward	Ward No	Type Of Source	Location Of Source	Date Of Sampling	Date Of Testing	Parameters																			Remark
										pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka	Fa	NO ₃	SO ₄	F	As	Total Col					
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26				
1	KHR/W/25-26/218	Alauli	Haripur	Haripur	2	Filter Water	Sandeep Memorial School	17-06-2025	18-06-2025	7.13	1	203	142	52.00	12.01	5.30	15.33	68.00	0.13	NT	NT	NT	<0.01	NT	Safe				
Desirable Limit										6.5-8.5	1	-	500	200	44	30	250	200	1	45	200	1	0.01	-					
Permissible Limit* in absence of alternative source										NR	5	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	-					

*NT = Not Tested, BDL = Below Detection Limit, NR = Not Relaxation

[Signature]
 Chemist
 18/06/25
 ANALYST
 P.H. DIVISION
 KHAGARIA

[Signature]

PRINCIPAL
 SANDEEP MEMORIAL SCHOOL
 HARIPUR, ALAULI, KHAGARIA

[Signature]
 MANAGER
 SANDEEP MEMORIAL SCHOOL
 HARIPUR, ALAULI, KHAGARIA